



## Wyckoff Fire Department Standard Operating Guideline

# 402.4.3

**Title: Dead End Street Engine  
Response**

**Date Issued: February 12, 1993**

**Date Last Revised: 7/1/09**

**Revision Number: 1**

**Total Pages: 1**

**PURPOSE:** All pump operators must be aware of dead end response for first due engines.

**OBJECTIVE:** This guideline sets the protocol for first and second due engines when a dead end response is encountered. Establishing a water supply and change over procedures is addressed.

### **GUIDELINE:**

When responding down a dead end street or driveway, if there has been a report of smoke or fire, the first arriving engine will lay a supply line either from a preceding hydrant or from the intersection at the entrance to the dead end location. They will then notify the second arriving engine and Command of their actions. It will then be the duty of the second arriving engine to complete the hose lay to the closest hydrant.

The second engine will connect the first engine directly to the hydrant providing immediate supply. The changeover of putting the second due engine onto the hydrant and in line to the first due engine will occur by command of the operator of the first engine.